



USE ONLY COPPER CONDUCTORS



TECHNICAL QUESTION?
CALL 1-800-247-4496

MODEL No.

4 DOOR LIGHTING
AUXILIARY DIAGRAM

DWG No.

65-1335-04

REV.

J

| DIMMING LEVEL | 1 | 2 | TIMING DELAY | 3 | 4 | LIGHT SENSITIVITY | 5 | DIMMING ON/OFF | 6 |
|---------------|-----|-----|--------------|-----|-----|-------------------|-----|----------------|-----|
| 0 | ON | ON | 30 SECONDS | ON | ON | POOR | ON | OFF | OFF |
| 10 | ON | OFF | 1 MINUTE | ON | OFF | GOOD | OFF | ACTIVATED | ON |
| 20 | OFF | ON | 2 MINUTE | OFF | ON | | | | |
| 50 | OFF | OFF | 8 MINUTE | OFF | OFF | | | | |

MOTION SENSOR SETTINGS: ↑ ON ↓ OFF